



GENERAL NOTES:

- A. ALL LIGHTS FIXTURES SHALL BE 120 VOLT, UNLESS OTHERWISE NOTED.
- B. SHADED FIXTURE SHALL BE EMERGENCY LIGHT FIXTURE WITH BATTERY BACKUP. BATTERY CONNECTED TO LOCAL UNSWITCHED LIGHTING CIRCUIT. CONNECT FIXTURE FOR CONTINUOUS OPERATION AS NIGHT LIGHT. UON. "EM" DESIGNATES FIXTURE TO BE SWITCHED WHERE INDICATED ON PLANS.
- C. ALL EXIT SIGNS AND NIGHT LIGHTS SHALL BE WIRED FOR CONTINUOUS OPERATION.
- D. MULTI-GANG BACKBOXES FOR DIFFERENT VOLTAGES AND TYPES OF EMERGENCY AND NORMAL BRANCH WIRING DEVICES SHALL HAVE DIVIDERS BETWEEN DEVICES.
- E. (1) EACH BRANCH CIRCUIT HOMERUN SHALL HAVE NO MORE THAN THREE CIRCUITS. EACH BRANCH CIRCUIT HOMERUN SHALL HAVE A SEPARATE GREEN INSULATED EQUIPMENT GROUNDING CONDUCTOR.
- F. FURNISH AND INSTALL 1000W RATED DIMMER SWITCH FOR CONTROL OF LIGHT FIXTURES AS INDICATED. DERATING IS REQUIRED IF MULTI-GANGED AND CONTROL FINS/SIDE SECTIONS ARE REMOVED. COORDINATE WITH DIMMER SWITCH MANUFACTURER'S INSTALLATION REQUIREMENTS.
- G. COORDINATE ALL UNDER CABINET LIGHTING WITH MILLWORK BEING INSTALLED AND ARCHITECTURAL ELEVATIONS. CONTRACTOR SHALL CONCEAL ALL CONDUIT.
- H. ALL FINAL LOCATIONS AND ARRANGEMENTS OF CEILING LIGHTING FIXTURES SHALL BE COORDINATED WITH OTHER TRADES.
- I. FURNISH AND INSTALL (1)3/4" WITH PLASTIC BUSHING AND PULL STRING FROM EACH LOW VOLTAGE LIGHTING CONTROL SWITCH TO ACCESSIBLE SPACE ABOVE CEILING FOR LOW VOLTAGE RELAY WIRING.

Ⓢ SHEET NOTES:

1. PROVIDE LIGHTING CONTROL PANEL "LCP" RELAY SWITCH LEGS PER RELAY SCHEDULE ON SHEET E0.3.
2. FOR CONTINUATION OF CIRCUIT IN STAIRWELL, SEE SHEETS E2.5, E2.7 AND E4.2.
3. FURNISH AND INSTALL LOW VOLTAGE WALLSTATION FOR OVERRIDE CONTROL OF NORMAL AND EMERGENCY POWER IN HALLWAY AND CORRIDOR LIGHTS. CIRCUIT AS INDICATED. SEE CONTROL DIAGRAMS SHEET E0.3.
4. LINE VOLTAGE MOTION SENSOR/PHOTOCELL. PHOTOCELL SHALL HAVE AUTO SET-POINT CALIBRATION, TWO SELECTABLE MODES OF OPERATION:
- ON/OFF MODE: PHOTOCELL HAS FULL CONTROL DURING PERIODS OF OCCUPANCY
 - INHIBIT MODE: PHOTOCELL CAN PREVENT LIGHTS FROM TURNING ON IF ADEQUATE DAYLIGHT IS AVAILABLE, BUT CAN NOT TURN LIGHTS OFF.
- AUTO SET STAIR MOTION SENSOR TO - ON/OFF MODE.
5. CIRCUIT LIGHT FIXTURES AND SWITCH IN ELEV EQUIP ROOM TO 120 VOLT RECEPTACLE CIRCUIT SHOWN ON SHEET E2.3. MAKE CONNECTIONS AS REQUIRED.

1THIRD FLOOR LIGHTING PLAN

95% SUBMISSION

CSHQ

C.W. MOORE PLAZA
250 S. 6TH ST. - BOISE, ID 83702
(208) 343-4835 - FAX (208) 343-1858
http://www.cshqa.com

AMY E. DOCKTER, P.E.
C.W. MOORE PLAZA
250 S. 6TH ST.
BOISE, IDAHO
PHONE: 208-343-4835 FAX: 208-343-1858

PRELIMINARY
NOT FOR
CONSTRUCTION

THIRD FLOOR
LIGHTING PLAN

APPROVED: DIVISION CHIEF

APPROVED: SERVICE DIRECTOR

PROJECT TITLE
VAMC
RENOVATE
BUILDING 33

BUILDING NUMBER
33

CHECKED
AKD

DRAWN
CRP

LOCATION
BOISE, IDAHO

DATE
03/04/11

PROJECT NO.
531-10-114

DRAWING NO.
E2.7

DWG. 88 OF 102

